

Biokube
Att. Peter Hedegaard
Åsidevej 1
4733 Tappernøje

Deres ref.:
ETA-DK

Vor ref.:
PF

Dato:
2005-11-15

Regarding: Declaration of EU Compliance.

This letter is drawn up to confirm, that BioKube Wastewater Treatment plants are certified and approved in Denmark in accordance to the specifications contained in the Danish Government Notice no. 500 of 21/6 1999 "Bekendtgørelse om typegodkendelsesordning for minirenselanlæg" (notice regarding certification of wastewater treatment plants).

The test procedure in Denmark is in accordance with the procedure described in EU prEN 12566 - Part 3: "Small Wastewater Treatment Systems for up to 50 PT – Part 3: Package and/or site assembled domestic wastewater treatment plants".

The maximum outlet values allowed for approval in Denmark – which the BioKube Wastewater Treatment plants are certified to fulfil - are:

BOD₅ (mod.) (mg/l) : 10

NH₃+NH₄-N (mg/l) : 5

Total-P (mg/l): 1,5

Med venlig hilsen
ETA-Danmark A/S

A handwritten signature in blue ink, appearing to read 'Peter Fritzel'.

Peter Fritzel